

Smoke and Heat Control Systems “WindowMaster”

Issued to

WindowMaster International A/S

Skelstedet 13, DK-2950 Vedbæk, Denmark

Product name

WindowMaster CompactSmoke™ WSC310/WSC320.

Product description

Smoke and heat control systems: Type D, electrical control panel with direct connection for detectors. Can be used for Comfort Ventilation. WindowMaster CompactSmoke™ WSC310/WSC320 shall be connected to Manual Contact Points of type WSK 501/502/ 503/ 504.

Certificate

The products described in this certificate have been type-examined by RISE and found to fulfil the requirements set out in standard ISO 21927-9:2012. Basis for this certificate is test report no. P113429.DP01.A01 dated 2023-02-22, issued by RISE Research Institutes of Sweden AB, Unit: *Electrification and Reliability - Safe Control Systems*.

Specification:

Operational Reliability: Re 1000
Environmental class 1

Marking

Each product that conforms in all respects with the original item type-examined may display the text 'Type examined by RISE'. When this marking is applied the marking shall also contain the information required by the actual standard, the number of this certificate and the serial number or equivalent of the item.

Validity

This certificate is valid until not later than 2028-04-03. The validity of this certificate can be verified by RISE.

Miscellaneous

Other terms and conditions are set out in RISE certification rules for type-examination, SPCR 123.

A blue ink signature of Martin Tillander, written in a cursive style.

Martin Tillander

Certificate C900860 | issue 1 | 2023-04-03

RISE Research Institutes of Sweden AB | Certification

Box 857, SE-50115 Borås, Sweden

+46 10 516 50 00 | certifiering@ri.se | www.ri.se

1179073

This document is the property of RISE and may not be reproduced other than in full, except with the prior written approval by RISE

Page 1 (1)