

# WSPCert Certificate

**No. BAC-0165-02**

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5:2012. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed in the annex of this certificate.

The BACnet Smart Actuator (B-SA)

**FlexiSmoke™  
WSA 5MC BACnet-IP**

with the software version:

**v1**

of

**WindowMaster A/S**

Skelstedet 13, 2950 Vedbæk, Denmark

has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 12.0 and the Certification Rules of the BACnet Interest Group Europe, see **MBS Test Report No. VG 2013\_8944**.

The certificate is valid  
until 2017/04/01

Date of renewal  
2016/03/31



2014/10/29

Date of initial certification



A handwritten signature in black ink, consisting of the letters 'C.L.' in a stylized, cursive font.

Dipl.-Ing. G. Weinmann  
Head of Certification Body

## Annex to Certificate No. BAC-0165-02

The certification of the BACnet Implementation  
**FlexiSmoke™ WSA 5MC BACnet-IP**  
of **WindowMaster A/S**

refers to the BACnet Interoperability Building Blocks (BIBBs) listed below. BIBBs other than listed are not part of the certification.

<b>BACnet Interoperability Building Blocks</b>	
DS-RP-B	Data Sharing – Read Property – B
DS-RPM-B	Data Sharing – Read Property Multiple – B
DS-WP-B	Data Sharing – Write Property – B
DS-COV-B	Data Sharing – COV – B
DM-DDB-B	Device Management – Dynamic Device Binding – B
DM-DOB-B	Device Management – Dynamic Object Binding – B