


WSC 520 - WSC 540 - WSC 560

Declaration of Performance / Leistungserklärung / Ydeevnedeklaration

(DoP)

 0402
WindowMaster International A/S, Skelstedet 13, DK-2950 Vedbæk 13 0402-CPR-SC0484-13
Electrical power supply equipment, intended to be used in smoke and heat controls systems. Elektrische Versorgungsgeräte, für den Einsatz in Rauch-und Wärmeabzugsanlagen. Elektrisk forsyningsudstyr, for anvendelse i forbindelse med brandventilation.
System 1
EN 12101-10 Operation class / Funktionsklasse / Funktionsklasse: A Environmental class / Umgebungsbedingungsklasse / Driftbetingelsesklasse: 1 IP rating / IP-Schutzart / Kapslingsklasse: IP 54 Interruption time / Unterbrechungszeit / Brydetid: < 2,0 sec Minimum Standby period / Min. Notstromversorgungszeit / Min. nødstrømforsyningstid: 72h Maximum capacity / Maximum Kapazität / Max kapacitet: WSC 520 2 x 18Ah WSC 540 4 x 18Ah WSC 560 6 x 18Ah Input / Versorgungsspannung / forsyningsspænding: WSC 520: 1 x 230 VAC 50 HZ (±10%) WSC 540: 2 x 230 VAC 50Hz (±10%) WSC 560: 400 VAC (3 x 230VAC) 50Hz (±10%) Output current (Imax b)/ Ausgangsstrom (Imax b) / Udgangsstrøm (Imax b): WSC 520 20A, WSC 540 40A, WSC 560 60A Output voltage / Ausgangsspannung / Udgangsspænding: 24 VDC ± 15%
WindowMaster International A/S: <i>N.K. Shabtai</i> (Nicolaj Rasmussen Shabtai, Chief Product Officer) Skelstedet 13, DK-2950 Vedbæk, 08 November 2019 Declaration no. WSC 5x0_DOC_1903

**UK
CA**

Supplied by

WindowMaster Control Systems Ltd

Lamport Close

Kettering Parkway- Kettering

Northants NN15 6XY

Tel.: +44 1536 614070

Fax: +44 1536 614071

info@windowmaster.co.uk

DK +45 4567 0300
UK +44 (0) 1536 510990
DE +49 (0) 5221 6940 -500 Vertrieb / -650 Technik
CH +41 (0) 62 289 22 22
Other markets +45 4567 0300



info@windowmaster.dk
info@windowmaster.co.uk
info@windowmaster.de
info@windowmaster.ch
info@windowmaster.com

www.windowmaster.com

WSC 520 - WSC 540 - WSC 560

Declaration of Performance

(DoP)

 Approval body: 1720
WindowMaster International A/S, Skelstedet 13, DK-2950 Vedbæk (1720-CPR-0243)
Electrical power supply equipment, intended to be used in smoke and heat controls systems.
System of assessment and verification of constancy of performance System 1
<p>EN 12101-10</p> <p>Operation class: A</p> <p>Environmental class: 1</p> <p>IP rating: IP 54</p> <p>Interruption time: < 2,0 sec</p> <p>Minimum Standby period: 72h</p> <p>Maximum capacity:</p> <p>WSC 520 2 x 18Ah</p> <p>WSC 540 4 x 18Ah</p> <p>WSC 560 6 x 18Ah</p> <p>Input:</p> <p>WSC 520: 1 x 230 VAC 50 HZ (±10%)</p> <p>WSC 540: 2 x 230 VAC 50Hz (±10%)</p> <p>WSC 560: 400 VAC (3 x 230VAC) 50Hz (±10%)</p> <p>Output current (Imax b):</p> <p>WSC 520 20A, WSC 540 40A, WSC 560 60A</p> <p>Output voltage: 24 VDC ± 15%</p>
<p>The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with CPR - Construction product regulation 2019, under the sole responsibility of WindowMaster International A/S.</p> <p>WindowMaster International A/S:  (Nicolaj Rasmussen Shabtai, Chief Product Officer)</p> <p>Skelstedet 13, DK-2950 Vedbæk, 24 May 2022 Declaration no. WSC 5x0_DOC_CE_UKCA 2205</p>